



ARNPRIOR

105 Elgin St. West  
Arnprior, ON K7S 0A8

Tel 613 623 4231  
Fax 613 623 8091

arnprior@arnprior.ca  
www.arnprior.ca

## Town of Arnprior 2021 – Water Filtration Plant Summary Report

February 2, 2022

Please find below a discussion of the operational undertakings of the Town of Arnprior's Water Filtration Plant (WFP) for the 2021 calendar year. This report is provided to meet the Town's requirements to report annually on the operation of the WFP, as per Municipal Drinking Water License (MDWL) 170-101 and Schedule 22 of O. Reg. 170/03 (Drinking Water Systems) and to provide residents of the Town of Arnprior with information on an important piece of the Town's municipal infrastructure.

### 1.0 Regulatory Reporting Requirements

Hereafter, for clarity all requirements of Schedule 22 of O. Reg. 170/03 are listed in blue italics below.

*22-2. (1) The owner of a drinking water system shall ensure that, not later than March 31 of each year after 2003, a report is prepared in accordance with subsections (2) and (3) for the preceding calendar year and is given to,*

*(a) in the case of a drinking water system owned by a municipality, the members of the municipal council.*

This report is to be presented the Council of the Town of Arnprior during the regular meeting of Council on March 28, 2022 reporting on the Arnprior Drinking Water System for the period covering January - December 2021.

*(2) The report must,*

*(a) list the requirements of the Act, the regulations, the system's approval, drinking water works permit, municipal drinking water licence, and any orders applicable to the system that were not met at any time during the period covered by the report; and*

The Town of Arnprior's Drinking Water System Number is 220000932 and is operated under Municipal Drinking Water Licence (MDWL) 170-101, Ver. 7. The Drinking Water Works Permit (DWWP) number is 170-201 Ver. 3 and the current Permit to Take Water (PTTW) is 4143-8ZDLMJ.

### 2.0 Compliance with Terms and Conditions of the MDWL

The Town of Arnprior owns and operates the Water Filtration Plant and complies with the

conditions of the DWWP, PTTW, and MDWL.

### **3.0 WFP Plant changes and Improvements**

- Elevated tower recoated on exterior, and interior cleaned and disinfected
- Chlorine gas maintenance performed by contractor
- Spill containment purchased and put into service
- Filter #1 pressure sensor replaced with new unit by contractor
- High lift pump surge relief valve re-furbished
- Purchased and replaced fluoride probe on analyzer
- Carry water backflow preventer for fluoride replaced and relocated into main building
- Facility sump pump replaced with new

In accordance with Ontario Regulation 107/03 all required sampling and laboratory analysis of the raw and treated water is carried out in the plant laboratory and a certified contracted laboratory, which includes annual, quarterly and weekly sampling requirements.

Flow meters are calibrated annually by an outside contractor for flow measurement of the water taken from the Madawaska River and to the distribution system.

Continuous water quality analyzers with alarm systems are installed for chlorine residual, turbidity of filtered water and fluoride residual.

All operators are certified to the appropriate level, with ongoing training taking place throughout the year.

### **4.0 Non-Compliance with Terms and Conditions of PTTW and MDWL**

*(2) The report must,*

*(b) for each requirement referred to in clause (a) that was not met, specify the duration of the failure and the measures that were taken to correct the failure.*

None during this reporting period.

### **5.0 Adverse Test Results and Other Operational Problems**

- On 25/Oct/21 the online fluoride analyzer was found to be reading erratic and would not calibrate. The fluoride dosing system was placed out of service due to lack of alarms from the analyzer. On 21/Oct/21 a new fluoride probe was installed and left to stabilize. On 25/Oct/21 the fluoride probe was calibrated and the fluoride dosing system was returned to service.
- No adverse test results during this reporting period

### **6.0 Water Production Flow Measurement**

The raw water and the backwash flows at the plant are measured by Endress + Hauser electromagnetic flow meters. These flow meters are calibrated annually by an outside contractor.

## **7.0 Raw Water Production**

*(3) The report must also include the following information for the purpose of enabling the owner of the system to assess the capability of the system to meet existing and planned uses of the system:*

*1. A summary of the quantities and flow rates of the water supplied during the period covered by the report, including monthly average and maximum daily flows.*

*2. A comparison of the summary referred to in paragraph 1 to the rated capacity and flow rates approved in the system's approval, drinking water works permit or municipal drinking water licence.*

The average daily raw water flow was measured at 4,589 m<sup>3</sup>. The maximum daily flow recorded was 7,227 m<sup>3</sup> on July 6, 2021 when the tower was being refilled after exterior paint was complete. The maximum daily flow permitted under the Town's current PTTW from the Madawaska River is 10,340 m<sup>3</sup>/day.

The total annual raw water flow for 2021 was 1,680,096 m<sup>3</sup>. This volume has decreased since 2020 which had a total flow of 1,691,619 m<sup>3</sup>, a slight decrease of 11,523 m<sup>3</sup>.

## **8.0 Treated Water Production**

The maximum daily volume of water permitted to be treated by the Town at the WFP under the MDWL in 2021 was 10,340 m<sup>3</sup>/day. There were no flow exceedances in 2021 and the average daily treated water flow was measured at 4,006 m<sup>3</sup>/day. The maximum daily treated water flow was 6,158 m<sup>3</sup> on July 6, 2021. The total annual treated water flow for 2021 was 1,462,599 m<sup>3</sup>. This volume is essentially the same as 2020 which had a total flow of 1,462,991 m<sup>3</sup>. The per capita use of water is 456 litres per day, based on a population of 8,795 which is above the typical Canadian average of 300-400 litres per day.

## **9.0 Backwash Water Production**

The average daily backwash water flow was 327m<sup>3</sup>. The total annual backwash water flow was 119,182m<sup>3</sup>. The backwash water is treated in a residuals treatment system where the solids are removed and pumped to the Water Pollution Control Centre (WPCC) for treatment and the clear supernatant is directed to the Madawaska River. The WFP MDWL stipulates a maximum permitted concentration of Total Suspended Solids (TSS) of 25 mg/l in the supernatant and in 2021 the average was 4.4 mg/l.

## **10.0 Water Quality**

The Town of Arnprior carries out all the sampling and analysis of the raw and treated water as per the requirements of the MDWL and O. Reg. 170/03, schedules 10, 13, 23 and 24. s. Certain parameters are done at different frequencies such as daily weekly, quarterly and annually.

### **11.0 Zebra Mussel**

Zebra mussels are evident at the Low Lift Pumphouse and at this time are manageable with semi annual cleaning of the intake screens.

### **12.0 Turbidity**

The Madawaska River is an excellent source of raw water with stable water turbidity. The performance criterion for filtered water is a turbidity of less than or equal to 0.3 Nephelometric Turbidity Units (NTU) in 95% of the measurements each month without exceeding 1.0 NTU. The 2021 filtered water turbidity was 0.09 NTU.

### **13.0 Quarterly and Annual Water Sampling**

Sampling and testing were carried out at various frequencies for Volatile Organic Compounds, Inorganic compounds, Pesticides and PCB as per Sch 23 and 24 of O Reg 170/03. These samples are taken by operators and sent to a certified laboratory. The analytical revealed that all samples were within acceptable concentrations under the Ontario Drinking Water Standards.

### **14.0 Hardness**

The recommended operational guideline for hardness is 80 mg/l expressed as Calcium Carbonate. This provides an acceptable balance between corrosion control and incrustation. Hardness is caused by the presence of certain dissolved chemical compounds with calcium and magnesium being the primary elements. The amount of hardness varies significantly depending on the source. The Arnprior raw water source has an average hardness of 47 mg/l which would be considered soft water.

### **15.0 Alkalinity**

Alkalinity is a measure of the capacity of water to neutralize acids and is known as the buffering capacity. The recommended operational range for alkalinity in treated drinking water is 30mg/l to 500mg/l as Calcium Carbonate. The Arnprior raw water has an average alkalinity of 36 mg/l and the treated water an average of 31 mg/l.

### **16.0 Fluoride**

Hydrofluorosilicic acid is added to the treated water to attain an average fluoride residual in 2021 of 0.64 mg/l with a Maximum Acceptable Concentration of 1.5 mg/l. The fluoride residual is monitored with an online analyzer and in laboratory analysis.

## **17.0 Water Treatment Chemicals**

The WFP uses Chlorine gas, polymer, Ammonium Sulphate (Chloramination), Polyaluminum Chloride (Coagulant), Sodium Carbonate (Soda Ash), Phosphoric Acid (Corrosion Control), and Hydrofluorosilicic Acid (Fluoride).

For inquiries regarding this report, please contact Scott Matthews at 623-4231 Ext. 1834.

Respectfully,

Scott Matthews  
Waterworks Supervisor